

STATE OF CONNECTICUT

DEPARTMENT OF PUBLIC HEALTH

Deidre S. Gifford, MD, MPH
Acting Commissioner



Ned Lamont
Governor
Susan Bysiewicz
Lt. Governor

Environmental Health Section

NOTICE OF EXCEPTION

An exception is hereby granted to the requirements of Section 19-13-B103d (d) of the Connecticut Public Health Code for a central subsurface sewage disposal system serving a church building and school classroom building located on the Slate Upper School property, 5100 Ridge Road in the Town of North Haven, Connecticut. A central system has been found to be technically preferable or the following reasons:

1. The Quinnipiack Valley Health District has indicated that a code complying subsurface sewage disposal system will be installed on the property capable of serving both structures.
2. The central system will provide an improved treatment and distribution of effluent.
3. The central system will simplify maintenance.

Recorded at the Connecticut Department of Public Health, Hartford, Connecticut.

03/08/2021

DATE

A handwritten signature in blue ink that reads "Matthew A. Pawlik".

Matthew A. Pawlik, P.E., R.S.
Sanitary Engineer III
Environmental Engineering Program



Phone: (860) 509-7296 • Fax: (860) 509-7295
Telecommunications Relay Service 7-1-1
410 Capitol Avenue, MS#12SEW, P.O. Box 340308
Hartford, Connecticut 06134-0308
www.ct.gov/dph

Affirmative Action/Equal Opportunity Employer

